

Certificate of Conformity


Certificate Number: CN-PVES-220286R1

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specifications /standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant Name & Address:	Shenzhen Growatt New Energy Co., Ltd. 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China
Product Description:	PV Grid inverter
Ratings & Principle Characteristics:	See Annex to Certificate of Conformity
Models/Type References:	MID 6KTL3-XL2, MID 8KTL3-XL2, MID 10KTL3-XL2, MID 11KTL3-XL2, MID 12KTL3-XL2, MID 15KTL3-XL2, MID 17KTL3-XL2, MID 20KTL3-XL2, MID 22KTL3-XL2, MID 25KTL3-XL2, MID 17KTL3-X2, MID 20KTL3-X2, MID 25KTL3-X2, MID 30KTL3-X2, MID 30KTL3-X2-1, MID 33KTL3-X2, MID 36KTL3-X2, MID 40KTL3-X2, MID 50KTL3-X2
Brand Name:	GROWATT
Specification/Standard:	IEC 61727:2004 Photovoltaic (PV) systems – Characteristics of the utility interface IEC 62116:2014 Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China
Test Report Number:	Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012 220908147GZU-001, Revision 1: 10 Dec 2024 220908147GZU-002, Revision 1: 10 Dec 2024

Replaces certificate CN-PV-220286 dated 15 December 2022

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 12 Dec. 2024



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-220286R1

Model	MID 6KTL3- XL2	MID 8KTL3- XL2	MID 10KTL3- XL2	MID 11KTL3- XL2	MID 12KTL3- XL2	MID 15KTL3- XL2	MID 17KTL3- XL2	MID 20KTL3- XL2	MID 22KTL3- XL2	MID 25KTL3- XL2
Max. DC voltage	800Vdc									
MPP voltage range	200-800Vdc									
Full-load voltage range	200-650Vdc									
No. of MPP trackers	2					4				
No. of PV strings per MPP trackers	2/2					2/2/2/2				
Max. input current per MPP trackers	32/36					32/32/32/32				
Max. short-circuit current per MPP trackers	40/45					40/40/40/40				
AC rated power	6000W	8000W	10000W	11000W	12000W	15000W	17000W	20000W	22000W	25000W
Max. AC apparent power	6600V A	8800V A	11100V A	12200V A	13300V A	16600V A	18800V A	22200V A	24400V A	27700V A
Nominal AC voltage	3W+PE, 3W/N/PE, 127V/220V; 133V/230V									
AC grid frequency	50/60 Hz									
Rated AC output current@127 V	15.7A	21.0A	26.2A	28.9A	31.5A	39.4A	44.6A	52.5A	57.7A	65.6A
Rated AC output current@133 V	15.0A	20.1A	25.1A	27.6A	30.1A	37.6A	42.6A	50.1A	55.1A	62.7A
Max. output current	17.5A	23.3A	29.2A	32.1A	35.0A	43.7A	49.6A	58.3A	64.2A	72.9A
Adjustable power factor	0.8Leading ...0.8Lagging									
Operating temperature range	-25°C ... +60°C (>45°C Derating)									
Protection degree	IP66									
Software Version	DM1.0									

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-220286R1

Model	MID 17KTL3- X2	MID 20KTL3- X2	MID 25KTL3- X2	MID 30KTL3- X2	MID 30KTL3- X2-1	MID 33KTL3- X2	MID 36KTL3- X2	MID 40KTL3- X2	MID 50KTL3- X2
Max. DC voltage	1100Vdc								
MPP voltage range	200-1000Vdc								
Full Load MPP voltage range	420-850Vdc		480-850Vdc		400-850Vdc			450-850Vdc	
No. of MPP trackers	2				3			4	
No. of PV strings per MPP trackers	2/2			2/3	2/2/2			2/2/2/2	
Max. input current per MPP trackers [A]	32/32		32/36	32/48	32/32/32			32/32/32/32	
Max. short-circuit current per MPP trackers [A]	40/40		40/45	40/60	40/40/40			40/40/40/40	
AC rated power [KW]	17	20	25	30	30	33	36	40	50
Max. AC apparent power [KVA]	18.8	22.2	27.7	33.3	30.0	36.6	40.0	44.4	55.5
Rated AC voltage	3W/N/PE, 230V/400V								
AC grid frequency	50/60Hz								
Rated AC output current [A]	24.6	29.0	36.2	43.5	43.5	47.8	52.2	58.0	72.5
Max. output current [A]	28.6	33.6	42.0	50.5	45.5	55.5	60.6	67.3	84.1
Adjustable power factor	0.8Leading ...0.8Lagging								
Operating temperature range	-25°C ... +60°C (>45°C Derating)								
Protection degree	IP66								
Software Version	DM1.0								

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.